



Appel d'offre international

Intitulé du marché	Fourniture de Transformateurs 6,6kV et 33kV
Référence de publication	67 - VESAU - 2025
Département bénéficiaire	Exploitation, Construction et ingénierie de réseaux électriques
Date de publication	12/11/2025
Date limite de soumission des offres	14/12/2025
Lieu d'exécution	Livraison : CIF - Port de Dar es Salaam, TANZANIE

Réponse aux questions des soumissionnaires

Q.1. Bonjour Monsieur / Madame

Pourriez-vous nous clarifier sur une valeur se trouvant sur les tableaux des valeurs :

K facteur THD	3
----------------------	----------

Faudrait on considérer THD 3 % ou K facteur 3 prière de nous revenir avec votre configuration pour que nous puissions avancer dans notre conception.

Excellente journée

R.1. / Il s'agit de 3% de THD

Q.2. /Dear Sir/Madam,

Reference is made to the tender mentioned above, kindly clarify the number of Virunga Energies personnel involved in the training package and the courses to be taken as stated in Annex II + III and price schedule.

Additionally, we are kindly requesting for an extension of the submission deadline for another 7 days to provide us with additional time to provide all the necessary requirements.

Kind regards,

Mercy.

R.2. / Dear Patner

Please note that for the training, we are planning for the participation of four VE employees.

Regarding your request, we regret to inform you that an extension of the submission deadline cannot be granted. The timeline established in the tender documents must be strictly respected, and no additional days can be added to the submission period.

We kindly encourage you to organize the remaining time accordingly to ensure the submission of all required documents within the established deadline.

Best regards